


TRANS



HRD-600SP series

Line Voltage SmartDIM Occupancy Sensor

INSTALLATION INSTRUCTIONS



w/Lens A/B/C

*More lens options are available for this sensor.
Please refer to the Lens Datasheet for more details.

APPLICABLE REMOTE (order separately)

Model	Description	Remarks
SRP-280	TRANS Remote Programmer	Full functionality
URP-100	User Remote	Manual ON/OFF/DIM TIME/LUX setting

⚠ WARNING & CAUTION

- Risk of Electric Shock - Disconnect power supply before servicing.
- Do NOT touch the square window of infrared sensor under the lens assembly.
- Open Type Photoelectric Switches.
- Cycling the power to the sensors will cause failure over time.

⚠ AVERTISSEMENT & PRUDENCE

- Risque de choc électrique - Débranchez l'alimentation avant l'entretien.
- Ne PAS toucher la fenêtre carrée de capteur infrarouge sous l'ensemble de l'objectif.
- Ouvrir Type commutateurs optoélectroniques.

OVERVIEW


The HRD-600SP series member of the TRANS family is a two-way IR remote programmable line voltage occupancy sensor with 0-10V output for 347/480VAC dimmable ballast or LED driver control. The sensor is capable of providing top-notch energy efficient lighting control in various modes with fully programmable multi-level high/low dim or SmartDIM control. SmartDIM is a state-of-the-art automatic dimming control technology developed by IR-TEC, which is capable of maintaining the overall ambient light level within the preset range through a smooth, flawless continuous dimming control to the connected lighting.

The sensor will turn on the connected lighting to the high dim or SmartDIM level as programmed when it detects the presence of an occupant or vehicle, and automatically dim the light down to the low level or shut off as programmed after the area is vacated for a period of time. An exclusive two-way handheld remote programmer (SRP-280) allows you to configure sensor setting, or download the existing settings of the installed sensor from the floor.

Like all PIR sensors of TRANS family, the HRD-600 series is also available with interchangeable lenses. The sensor can be externally mounted with a lighting fixture via a 1/2" knockout hole, and operate in the coldest of environments, down to -40°F/°C.

SENSOR MOUNTING

Light Fixture (Top View)




Note: For IP-66 fixture integration, ensure the rubber gasket is placed in between the fixture enclosure and sensor unit.

LENS OPTIONS

Different lenses can be applied to provide specific coverage at different mounting heights. Please refer to the lens datasheet attached for more details.

APPLICATION NOTES

1. The sensor is more sensitive to the movements "crossing" the detection zones than "toward" or "away" the sensor unit. To obtain better sensitivity, avoid placing the sensor in line with occupant path, if possible.
2. The closer the movement is to the sensor, the more sensitive the sensor is. The higher the sensor is installed, the larger movement is required to be detected.
3. Ensure to place the sensor at least at 1.5m (5 ft.) away from air supply ducts as rapid air flow may cause false activations.
4. The sensor cannot "see" the movements behind obstacles, such as furniture, shelf, glass or partition. As a general rule, each occupant should be able to clearly view the sensor unit.
5. For open office areas with partition which could block the sensor view to occupant movements, it is best to place the sensors over the intersection of multiple workstations. For large areas of open office or space, place multiple sensors so that there is overlap coverage with each adjacent sensor.



Tested LED Driver/Electronic Ballast (for reference)

Manufacturer	Model no.	Rating
MEAN WELL	HVG-320-48B	480 VAC, 4.5 A
THOMAS	PLED96W-046-C2100-D-HV	480 VAC, 0.2 A
EVERLINE	D10CC150HV10F	480 VAC, 0.34 A
PHILIPS	XH150C070V210CNF1	480 VAC, 0.35 A



www.irtec.com

P/N: 058-60013-002

Printed in Taiwan

This product may be covered by one or more U.S. patents or patent applications.
Please visit www.irtec.com for more information.



CONTROL MODE

The HRD-600SP sensor can be programmed by SRP-280 remote programmer to control the lighting in one of the following modes. For more details of specific control mode, please visit www.irtec.com or contact an IR-TEC team member directly.

ON/OFF : ON-OFF Switching

OSO : Occupancy Sensing Only

OSLA : Occupancy Sensing at Low Ambient

OSLATO : Occupancy Sensing at Low Ambient with Time-Off

OFF : Light OFF all the time

Mode	Control
ON/OFF	1. While ambient lux is higher than the level set, light stays OFF . 2. While ambient lux is lower than the level set, and occupancy detected , switch the light to HIGH DIM . 3. Turn OFF the light after occupant leave and delay time elapses.
OSO	1. Ambient light sensor disabled. 2. Dim the light to LOW DIM at all time under vacancy. 3. Switch the light to HIGH DIM under occupancy. 4. Dim the light to LOW DIM after occupant leave and delay time elapses.
OSLA	1. While ambient lux is higher than the level set, light stays OFF . 2. While ambient lux is lower than the level set, dim the light to LOW DIM under vacancy. 3. While ambient lux is lower than the level set, and occupancy detected , switch the light to HIGH DIM . 4. Dim the light to LOW DIM after occupant leave and delay time elapses.
OSLATO	1. While ambient lux is higher than the level set, light stays OFF . 2. While ambient lux is lower than the level set, and occupancy detected , switch the light to HIGH DIM . 3. Dim the light to LOW DIM after occupant leave and delay time elapses. 4. Turn OFF the lights when TIME OFF delay elapses. 5. When occupancy detected during TIME OFF , switch the light to HIGH DIM .
OFF	1. All lighting controlled by the sensor will remain OFF until another mode is selected.

SENSOR ACKNOWLEDGMENT

Acknowledgement	Sensor LED	Beep	Lighting
Full sensor setting upload completed	-	Long x 1 Short x 2	Flash x 2
Sensor resume to factory default	-	-	Flash x 2
SmartDIM level set completed	-	Short x 2	Flash x 2
Single setting ok	-	Short x 2	-
Occupancy detected	Flash x 1	-	-


SENSOR SETTINGS

The followings are settings and options available with HRD-600SP that can be configured through the operation of SRP-280 remote programmer. For more details of remote sensor setting, please refer to the operation instruction of SRP-280.


Settings	Description	Options	Default
CONTROL	The mode that the sensor will control.	ON/OFF, OSO, OSLA, OSLATO, OFF	OSLATO
AMBIENT LUX	The ambient light level that sensor will perform the control.	10/20/40/60/100/200/400 LUX/DISABLED	DISABLED
DELAY	The delay time that sensor is set to turn off or dim the light.	30 sec./1/3/5/10/15/20/30/60 min.	10 min.
TIME OFF	The delay time that sensor will keep the light at low dim level after the OFF delay time elapsed. Only available if OSLATO is selected.	10/30 sec./3/5/10/15/20/30/45/60 min.	10 min.
HIGH DIM	The output level set to control the light during occupancy.	50/55/60/65/70/80/90/100%/SmartDIM	100%
LOW DIM/SmartDIM	The output level set to dim the light when space is vacant for bi-level control. Low dim setting will become SmartDIM bar if SmartDIM control is selected.	0/5/10/15/20/25/30/40%	30%
RAMP UP	The speed of increasing the lighting output to HIGH DIM level.	INSTANT/SOFT/SLOW	INSTANT
FADE DOWN	The speed of decreasing the lighting output to LOW DIM level or off.	INSTANT/SOFT/SLOW	SOFT
LED INDICATOR	Enable/disable the LED indicator of sensor.	ENABLED/DISABLED	ENABLED
SENSITIVITY	The sensitivity of occupancy sensor.	HIGH/NORMAL/LOW	HIGH
MIN. DIM	The lowest dim level applicable on the sensor.	12%/15%/DISABLED	DISABLED
DAY O'RIDE	Enable/disable daylight override control. Sensor will shut off the light when ambient lux exceeds the override level set below. Only available if AMBIENT LUX is enabled.	ENABLED/DISABLED	DISABLED
O'RIDE LEVEL	The ambient lux level to enable daylight override. Only available if DAY O'RIDE is enabled.	HIGH(~1.8X)/NORMAL(~1.5X)/LOW(~1.3X)	NORMAL

Wiring Diagram

A. Single Phase Line Power (347 VAC)



B. 2-Phase Line Power (480 VAC)



SPECIFICATIONS

Power voltage	347/480 VAC, 60Hz	
Maximum load	347 VAC	480 VAC
-Ballast Electronic (LED)	1500 VA	2160 VA
Infrared sensor	Omni-directional pyroelectric	
Photo sensor	Digital ambient light sensor	
Load switching	Zero-cross control relay	
Dim control output	0-10V, $\pm 5\%$, max 25 mA sinking current	
Detectable speed	0.5~10 ft./sec. (0.15 ~ 3 m/sec.)	
Mounting height	Subject to the lens type applied	
Detection range	Subject to the lens applied and height	
Remote range	33 ft (10 m) indoor	
Op. humidity	Max. 95% RH	
Op. temperature	-40°F~122°F (-40°C~50°C)	
Dimensions	H4.37" x W3.54" x D1.8" (H111 x W90 x D46mm)	